

**NOTICE TO CONSUMERS OF THE
CLARKE COUNTY SANITARY AUTHORITY WATERWORKS
IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

Monitoring Requirements Not Met For Clarke County Sanitary Authority

We have been advised by state health officials of a failure to perform required monitoring in accordance with the Commonwealth of Virginia/State Board of Health *Waterworks Regulations*.

We are required to monitor your drinking water for specific contaminants on a regular basis and measure and report free chlorine residuals. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the March 2010 compliance period we did not measure and report the free chlorine residual concentration with one of our routine coliform bacteria samples.

What This Means

There is nothing you need to do at this time. We are required to measure and report free chlorine residual with each coliform bacteria sample. We did not do the required testing for the March 4, 2010 sample; however, we did include the chlorine residual on the March 16, 2010 sample. There was no coliform present in the March samples. Two samples are due to be collected in April 2010.

Steps We Are Taking

We will collect two samples during April 2010 in accordance with our approved Bacteriological Sample Siting Plan and will include the chlorine residual readings on both samples.

For more information, please contact Mr. Michael Legge at 540-955-5185 or P.O. Box 327, Berryville, VA 22611.

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting the notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the Clarke County Sanitary Authority.

State Water System ID#: 2043250

Date Distributed 5/28/2010